# NOBLES COUNTY SUBSURFACE SEWAGE TREATMENT SYSTEM (SSTS) ORDINANCE



## **TABLE OF CONTENTS**

719.		Subsurface Sewage Treatment Systems (SSTS)	5
719.1		Purpose	5
719.2		Intent	6
719.3		Authority	6
719.4		Effective Date	6
719.5		Definitions	6
719.6		General Provisions	10
1.0		Scope	10
2.0		Jurisdiction	10
719.7		Administration	10
1.0		County Administration	10
2.0		State of Minnesota.	10
3.0		Cities and Townships	11
4.0		Validity	11
5.0		Liability	11
719.8		General Requirements	11
1.0		Retroactivity	11
	a.	All SSTS	11
	b.	Existing Permits	11
	C.	SSTS on Lots Created after January 23, 1996	11
2.0		Upgrade, Repair, Replacement, and Abandonment	11
	a.	SSTS Capacity Expansions	11
	b.	Addition to Dwellings	12
3.0		Failure to Protect Groundwater	12
4.0		Imminent Threat to Public Health or Safety	12
5.0		Abandonment	12
6.0		SSTS in Floodplains	12
7.0		Class V Injection Wells	12
8.0		SSTS Practitioner Licensing	12
9.0		Prohibitions	12
	a.	Occupancy or Use of a Building without a Compliant SSTS	12
	b.	Sewage Discharge to Ground Surface or Surface Water	13
	C.	Sewage Discharge to a Well or Boring	13
	d.	Discharge of Hazardous or Deleterious Materials	13
719.9		SSTS Standards	13
1.0		Standards Adopted by Reference	13
2.0		Amendments to the Adopted Standards	13
	a.	Determination of Hydraulic Loading Rate and SSTS Sizing	13
	b.	Compliance Criteria for Existing SSTS	13
3.0		Holding Tanks	14
719.10		Variances	15

1.0	Variance Request	15
2.0	Affected Agency	15
3.0	Board of Adjustment	15
719.11	SSTS PERMITING	16
1.0	Permits Required	16
2.0	SSTS Permit	16
3.0	Activities Requiring a Construction Permit	17
4.0	Construction Permit Required to Obtain Building Permit	17
5.0	Conformance to Prevailing Requirements	17
6.0	Permit Application Requirements	17
7.0	Application Review and Response	17
8.0	Appeal	18
9.0	Permit Expiration	18
10.0	Extensions and Renewals	18
11.0	Transferability	18
12.0	Suspension or Revocation	18
13.0	Posting	18
719.12	Operating Permit	18
1.0	SSTS Requiring an Operating Permit	18
2.0	Permit Application Requirements	19
3.0	Owners of Holding Tanks	19
4.0	Existing SSTS	19
5.0	Department Response	19
6.0	Operating Permit Terms and Conditions	19
7.0	Permit Expiration and Renewal	20
8.0	Amendments to Existing Permits not Allowed	20
9.0	Transfers	21
10.0	Revocation	22
11.0	Compliance Monitoring	21
719.13	Abandonment Certification	22
1.0	Purpose	22
2.0	Abandonment Requirements	22
3.0	Abandonment Certificate	23
719.14	Management Plans	23
1.0	Purpose	23
2.0	SSTS Requiring Management Plans	23
3.0	Required Contents of a Management Plan	23
4.0	Requirements for Systems not Operated under a Management	23
	Plan	
719.15	Compliance Management	24
1.0	Public Education Outreach	24
2.0	Compliance Inspection Program	24
3.0	New Construction or Replacement	25

4.0	Existing Systems	25
719.16	Transfer of Properties with Existing SSTS	27
719.17	Enforcement	29
1.0	Enforcement of Regulations	29
2.0	Cause to Issue a Notice of Violation	29
3.0	Notice of Violation	29
4.0	State Notification of Violation	29
5.0	Cease and Desist Orders	30
719.18	Costs and Reimbursements	30
719.19	Record Keeping	30
719.20	Annual Report	30
719.21	Fees	30
719.22	Interpretation	31
719.23	Severability	31
719.24	Abrogation and Greater Restrictions	31
719.25	Ordinance Repealed	31
719.26	Adoption	31
	Forms	

## 719. SUBSURFACE SEWAGE TREATMENT SYSTEMS (SSTS)

## 719.1 <u>Purpose</u>

The purpose of this ordinance is to establish minimum requirements for regulation of Subsurface Sewage Treatment Systems (SSTS) for the treatment and dispersal of sewage within the applicable jurisdiction of the County to protect public health and safety, groundwater quality, and prevent or eliminate the development of public nuisances. It is intended to serve the best interests of the County's citizens by protecting its health, safety, general welfare, and natural resources.

## 719.2 Intent

It is intended by the County that this Ordinance will promote the following:

- 1. The protection of lakes, rivers and streams, wetlands, and groundwater in Nobles County essential to the promotion of public health, safety, welfare, socioeconomic growth and development of the County.
- 2. The regulation of proper SSTS construction, reconstruction, repair and maintenance to prevent the entry and migration of contaminants, thereby protecting the degradation of surface water and groundwater quality.
- 3. The establishment of minimum standards for SSTS placement, design, construction, reconstruction, repair and maintenance to prevent contamination and, if contamination is discovered, the identification and control of its consequences and the abatement of its source and migration.
- 4. The appropriate utilization of privy vaults and other non-water carried sewage collection and storage facilities.
- 5. The provision of technical assistance and education, plan review, inspections, SSTS surveys and complaint investigations to prevent and control waterborne diseases, lake degradation, groundwater related hazards, and public nuisance conditions.

## 719.3 Authority

This Ordinance is adopted pursuant to Minnesota Statutes, Section 115.55; Minnesota Statutes, Sections 145A.01 through 145A.08; Minnesota Statutes, Section 375.51; or successor statutes, and Minnesota Rules, Chapter 7080, Chapter 7081, Chapter 7082, or successor rules.

## 719.4 Effective Date

The provisions set forth in this Ordinance shall become effective on after its passage, publication, and recording as provided by law.

## 719.5 <u>Definitions</u>

The following words and phrases shall have the meanings ascribed to them in this Article. If not specifically defined in this Article, terms used in this Ordinance shall have the same meaning as provided in the standards adopted by reference. Words or phrases that are not defined here or in the standards adopted by reference shall have common usage meaning. For purposes of this Ordinance, the words "must" and "shall" are mandatory and the words "may" and "should" are permissive.

**Authorized Representative:** Nobles County Environmental Services Director or appointee.

**Board of Adjustment:** A board established by county ordinance with the authority to order the issuance of variances, hear and decide appeals from a member of the affected public and review any order, requirement, decision, or determination made by any administrative official charged with enforcing any ordinance adopted pursuant to the provision of Minnesota Statutes, sections 394.21 to 394.37, order the issuance of permits for buildings in areas designated for future public use on an official map and perform such other duties as required by the official controls.

Class V Injection Well: A shallow well used to place a variety of fluids directly below the land surface. This includes SSTS that are designed to receive sewage or nonsewage from a two-family dwelling or greater or receive sewage or nonsewage from another establishment that serves more than 20 persons per day. The US Environmental Protection Agency and delegated state groundwater programs permit these wells to inject wastes below the ground surface provided they meet certain requirements and do not endanger underground sources of drinking water. Class V motor vehicle waste disposal wells and large-capacity cesspools are specifically prohibited (see 40 CFR Parts 144 & 146).

**Cluster System:** A SSTS under some form of common ownership that collects wastewater from two or more dwellings or buildings and conveys it to a treatment and dispersal system located on an acceptable site near the dwellings or buildings.

County: Nobles County, Minnesota.

**County Board:** The Nobles County Board of Commissioners.

**Department:** The Nobles County Environmental Services Department.

**Design Flow:** The daily volume of wastewater for which an SSTS is designed to treat and discharge.

**Failure to Protect Groundwater:** At a minimum, a SSTS that does not protect groundwater is considered to be a seepage pit, cesspool, drywell, leaching pit, or other pit; a SSTS with less than the required vertical separation distance, described in MR Chapter 7080.1500 Subp. 4 D and E; and a system not abandoned in accordance with part 7080.2500. The determination of the threat to groundwater for other conditions must be made by a Qualified Employee or an individual licensed pursuant to Section 719.15 hereof.

Imminent Threat to Public Health and Safety: At a minimum a SSTS with a discharge of sewage or sewage effluent to the ground surface, drainage systems, ditches, or storm water drains or directly to surface water; SSTS that cause a reoccurring sewage backup into a dwelling or other establishment; SSTS with electrical hazards; or sewage tanks with unsecured, damaged, or weak maintenance access covers. The determination of protectiveness for other conditions must be made by a Qualified Employee or a SSTS inspection business licensed pursuant to Section 5 hereof.

**ISTS:** An individual sewage treatment system having a design flow of no more than 5,000 gallons per day.

**Industrial Waste:** Sewage containing waste from activities other than sanitary waste from industrial activities including, but not limited to, the following uses defined under the Standard Industrial Classification (SIC) Codes established by the U.S. Office of Management and Budget.

SIC	INDUSTRY CATEGORY
CODE(S)	Automative Deneiro and Comices
753-7549 7231,7241	Automotive Repairs and Services
7231,7241 7211-7219	Beauty Shops, Barber Shops Laundry Cleaning and Garment Services
4011-4581	Transportation (Maintenance only)
8062-8069	Hospitals
2000-3999	Manufacturing
2000-3999	Food Products
2100-2199	Tobacco Products
2400-2499	Lumber and Wood Products, except Furniture
2500-2599	Furniture and Fixtures
2600-2699	Paper and Allied Products
2700-2799	Printing, Publishing, and Allied Industries
2800-2899	Chemicals and Allied Products
2900-2999	Petroleum Refining and Related Industries
3000-3099	Rubber and Miscellaneous Plastics
3100-3199	Leather Tanning and Finishing
3000-3099	Rubber and Miscellaneous Plastics
3100-3199	Leather Tanning and Finishing
3200-3299	Stone, Clay, Glass, and Concrete Products
3300-3399	Primary Metal Industries
3400-3499	Fabricated Metal Products (except Machinery, and
	Transportation Equipment
3500-3599	Industrial and Commercial Machinery and Computer
	Equipment
3700-3799	Transportation Equipment
3800-3899	Measuring, Analyzing, and Controlling Instruments;
	Photographic, Medical and Optical Goods; Watches and
	Clocks
3900-3999	Miscellaneous Manufacturing Industries

**LSTS:** A "large subsurface sewage treatment system" under single ownership that receives sewage from dwellings or other establishments having a design flow of 10,000 gallons per day or greater.

**Malfunction:** The partial or complete loss of function of a SSTS component, which requires a corrective action to restore its intended function.

**Management Plan:** A plan that describes necessary and recommended routine operational and maintenance requirements, periodic examination, adjustment, and testing, and the frequency of each to ensure system performance meets the treatment expectations, including a planned course of action to prevent an illegal discharge.

**Minor Repair:** The repair or replacement of an existing damaged or faulty component/part of an SSTS that will return the SSTS to its operable condition. The repair shall not alter the original area, dimensions, design, specifications or concept of the SSTS.

**MSTS:** A "midsized subsurface sewage treatment system" under single ownership that receives sewage from dwellings or other establishments having a design flow of more than 5,000 gallons per day to a maximum of 10,000 gallons per day.

**Notice of Noncompliance:** A written document issued by the Department notifying a system owner that the owner's onsite/cluster treatment system has been observed to be noncompliant with the requirements of this Ordinance.

MPCA: Minnesota Pollution Control Agency.

**Qualified Employee:** An employee of the state or a local unit of government, who performs site evaluations or designs, installs, maintains, pumps, or inspects SSTS as part of the individual's employment duties and is registered on the SSTS professional register verifying specialty area endorsements applicable to the work being conducted.

**Record Drawings:** A set of drawings which to the fullest extent possible document the final in-place location, size, and type of all SSTS components including the results of any materials testing performed and a description of conditions during construction of the system.

**Sewage:** Waste from toilets, bathing, laundry, or culinary activities or operations or floor drains associated with these sources, including household cleaners and other constituents in amounts normally used for domestic purposes.

**SSTS:** Subsurface sewage treatment system including an ISTS, MSTS or LSTS.

State: The State of Minnesota.

**Treatment Level:** Treatment system performance levels defined in Minnesota Rules, Chapter 7083.4030, and Table III for testing of proprietary treatment products, which include the following:

<u>Level A:</u> cBOD<sub>5</sub>  $\leq$  15 mg/L; TSS  $\leq$  15 mg/L; fecal coliforms  $\leq$  1,000/100 mL.

<u>Level A-2:</u> cBOD<sub>5</sub>  $\leq$  15 mg/L; TSS  $\leq$  15 mg/L; fecal coliforms <u>N/A</u>.

<u>Level B:</u>  $cBOD_5 \le 25 \text{ mg/L}$ ;  $TSS \le 30 \text{ mg/L}$ ; fecal coliforms  $\le 10,000/100 \text{ mL}$ .

<u>Level B-2:</u> cBOD<sub>5</sub>  $\leq$  25 mg/L; TSS  $\leq$  30 mg/L; fecal coliforms N/A. <u>Level C:</u> cBOD<sub>5</sub>  $\leq$  125 mg/L; TSS  $\leq$  60 mg/L; O&G  $\leq$ 25mg/L; fecal coliforms N/A.

**Type I System:** An ISTS that follows a standard trench, bed, at-grade, mound, or graywater system design in accordance with MPCA rules, Minnesota Rules, Chapter 7080.2200 through 7080.2240.

**Type II System:** An ISTS with acceptable modifications or sewage containment system that may be permitted for use on a site not meeting the conditions acceptable for a standard Type I system. These include systems on lots with rapidly permeable soils or lots in floodplains and privies or holding tanks in accordance with MPCA rules Minnesota Rules Chapter 7080.2250 through 7080.2290.

**Type III System:** A system designed according to the requirements with Minnesota Rules Chapter 7080.2300.

**Type IV System:** An ISTS, having an approved pretreatment device and incorporating pressure distribution and dosing, that is capable of providing suitable treatment for use in accordance with MPCA rules Minnesota Rules Chapter 7080.2350. The system must be designed by an Advanced Designer and inspected by an Advanced Inspector.

**Type V System:** An ISTS, which is a custom engineered design to accommodate the site taking into account pretreatment effluent quality, loading rates, loading methods, groundwater mounding, and other soil and other relevant soil, site, and wastewater characteristics such that groundwater contamination by viable fecal coliforms is prevented in accordance with MPCA rules Minnesota Rules Chapter 7080.2400. The system must be designed by an Advanced Designer and inspected by an Advanced Inspector.

## 719.6 General Provisions

- 1. Scope. This Ordinance regulates the siting, design, installation, alterations, operation, maintenance, monitoring, and management of all SSTS within the County's applicable jurisdiction including, but not necessarily limited to individual SSTS and cluster or community SSTS, privy vaults, and other non-water carried SSTS. All sewage generated in unsewered areas of the County shall be treated and dispersed by an approved SSTS that is sited, designed, installed, operated, and maintained in accordance with the provisions of this Ordinance or by a system that has been permitted by the MPCA.
- 2. Jurisdiction. The jurisdiction of this Ordinance shall include all lands of the County except for incorporated areas that administer a Subsurface Sewage Treatment System (SSTS) program by Ordinance within their incorporated jurisdiction, which is at least as strict as this Ordinance and has been approved by the County. The Nobles County Environmental Services shall keep a current list of local jurisdictions within the County administering an SSTS program.

## 719.7 Administration

## 1. County Administration

The Nobles County Environmental Services Department shall administer the SSTS program and all provisions of this Ordinance. At appropriate times, the County shall review this and revise and update this Ordinance as necessary. The County shall employ or retain under contract qualified and appropriately licensed professionals to administer and operate the SSTS program.

#### 2. State of Minnesota

Where a single SSTS or group of SSTS under single ownership within one-half mile of each other, have a design flow greater than 10,000 gallons per day, the owner or owners shall make application for and obtain a State Disposal System permit from MPCA. For any SSTS that has a measured daily flow for a consecutive seven-day period which equals or exceeds 10,000 gallons per day, a State Disposal System permit is required.

SSTS serving establishments or facilities licensed or otherwise regulated by the State shall conform to the requirements of this Ordinance.

## 3. Cities and Townships

Any jurisdiction within the County that regulates SSTS must comply with the standards and requirements of this Ordinance. The standards and ordinance of the jurisdiction may be administratively and technically more restrictive than this Ordinance.

## 4. Validity

The validity of any part of this Ordinance shall not be affected by the invalidity of any other parts of this Ordinance where the part can be given effect irrespective of any invalid part or parts.

## 5. Liability

Any liability or responsibility shall not be imposed upon the department or agency or any of its officials, employees, or other contract agent, its employees, agents or servants thereof for damage resulting from the defective construction, operation, or abandonment of any onsite or cluster treatment system regulated under this rule by reason of standards, requirements, or inspections authorized hereunder.

## 719.8 General Requirements

## 1. Retroactivity

a. All SSTS. Except as explicitly set forth in Section 719.8 (1) b, all provisions of this Ordinance shall apply to any SSTS regardless of the date it was originally permitted.

- b. Existing Permits. Unexpired permits which were issued prior to the effective date shall remain valid under the terms and conditions of the original permit until the original expiration date or until a change in system ownership whichever is earlier.
- c. SSTS on Lots Created After January 23, 1996. All lots created after January 23, 1996 must have a minimum of two soil treatment and dispersal areas that can support trenches, seepage beds, mounds, atgrade systems or rapidly permeable soils as described in Minnesota Rules, Chapters 7080. 2200 through 7080.2230 and 7080.2260 or site conditions described in 7081.0270. Subp. 3 through 7.
- 2. Upgrade, Repair, Replacement, and Abandonment
  - a. SSTS Capacity Expansion. Expansion of an existing SSTS must include any system upgrades that are necessary to bring the entire system into compliance with the prevailing provisions of this Ordinance at the time of the expansion.
  - b. Additions to Dwellings. The owner must submit an inspection, valid Certificate of Compliance and/or obtain a valid SSTS Septic Permit prior to the issuance of a Zoning Certificate for an addition to a dwelling that increases the number of bedrooms in the dwelling.
- 3. Failure to Protect Groundwater. An SSTS that is determined not to be protective of groundwater in accordance with Minnesota Rules, Chapter 7080.1500,Subp.4.B shall be upgraded, repaired, replaced or abandoned by the owner in accordance with the provisions of this Ordinance within 12 months of receipt of a Notice of Noncompliance.
- 4. Imminent Threat to Public Health or Safety. An SSTS that is determined to be an imminent threat to public health or safety in accordance with Minnesota Rules, Chapter 7080.1500,Subp.4A shall be upgraded, repaired, replaced or abandoned by the owner in accordance with the provisions of this Ordinance within 10 months of receipt of a Notice of Noncompliance.
- 5. Abandonment. Any SSTS, or any component thereof, which is no longer intended to be used, must be abandoned in accordance with Minnesota Rules, Chapter 7080.2500.
- 6. SSTS in Floodplains. SSTS shall not be located in a floodway and wherever possible, location within any part of a floodplain shall be avoided. If no option exists to locate a SSTS outside of a floodplain, location within the flood fringe is allowed if the requirements in Minnesota Rules, Chapter 7080.2270 and all relevant local requirements are met.
- 7. Class V Injection Wells. All owners of new or replacement SSTS that are considered to be Class V injection wells, as defined in the Code of Federal Regulations, title 40, part 144, are required by the Federal Government to submit SSTS inventory information to the Environmental Protection Agency

- as described in CFR40 part 144. Further, owners are required to identify all Class V injection wells in property transfer disclosures.
- 8. SSTS Practitioner Licensing. No person shall engage in site evaluation, inspection, design, installation, construction, alternation, extension, repair, maintenance, or pumping of SSTS without an appropriate and valid license issued by MPCA in accordance with Minnesota Rules, Chapter 7083 except as exempted in 7083.0700. Owners who wish to install or construct their own system must sign an agreement indemnifying the county against claims due to the failure of the owner to comply with the provisions of this ordinance.

## 9. Prohibitions

- a. Occupancy or Use of a Building without a Compliant SSTS. It is unlawful for any person to maintain, occupy, or use any building intended for habitation that is not provided with a wastewater treatment system that disposes of wastewater in a manner that does not comply with the provisions of this Ordinance.
- b. Sewage Discharge to Ground Surface or Surface Water. It is unlawful for any person to construct, maintain, or use any SSTS system regulated under this Ordinance that results in raw or partially treated wastewater seeping to the ground surface or flowing into any surface water. Any surface discharging system must be permitted under the National Pollutant Discharge Elimination System program by the MPCA.
- c. Sewage Discharge to a Well or Boring. It is unlawful for any person to discharge raw or treated wastewater into any well or boring as described in Minnesota Rules, Chapter 4725.2050, or any other excavation in the ground that is not in compliance with this ordinance.
- d. Discharge of Hazardous or Deleterious Materials. It is unlawful for any person to discharge into any treatment system regulated under this Ordinance any hazardous or deleterious material that adversely affects the treatment or dispersal performance of the system or groundwater quality.

## 719.9 SSTS Standards

- 1. Standards Adopted by Reference. The County hereby adopts by reference Minnesota Rules, Chapters 7080 and 7081 in their entirety as now constituted and from time to time amended. This adoption does not supersede the County's right or ability to adopt local standards that are in compliance with Minnesota Statute 115.55.
- 2. Amendments to the Adopted Standards.
  - a. Determination of Hydraulic Loading Rate and SSTS Sizing
    - 1. Tables IX from Minnesota Rules, Chapter 7080.2150, Subpart 3(E) entitled "Loading Rates for Determining Bottom Absorption

Area for Trenches and Seepage Beds for Effluent Treatment Level C and Absorption Rations for Determining Mound Absorption Areas Using Detail Soil Description" and herein adopted by reference shall be used to determine the hydraulic loading rate and infiltration area for all SSTS permitted under this section.

 The Department will make the determination whether a pit will be required for soil verification for ISTS. A pit will be required for all systems with 5,000 gallons or more design flow, MSTS or LSTS.

## b. Compliance Criteria for Existing SSTS

- SSTS built before April 1, 1996 outside of areas designated as shoreland areas, wellhead protection areas, or SSTS providing sewage treatment for food, beverage, or lodging establishments must have at least two (2) feet of vertical separation between the bottom of the dispersal system and seasonal saturation or bedrock.
- 2. SSTS built after March 31, 1996, or SSTS located in a shoreland area, wellhead protection area, or serving a food, beverage, or lodging establishment as defined under Minnesota Rules, Chapter 7080.1100, Subp. 84, shall have a three (3) foot vertical separation between the bottom soil infiltrative surface and the periodically saturated soil and/or bedrock. When determining vertical separation distance, a variance reduction of up to five (5) inches will be allowed to account for settling of sand or soil, normal variation of separation distance measurements, and interpretation of limiting layer conditions.
- 3. The vertical separation measurement for 1.) and 2.) above shall be made outside the area of system influence but in an area of similar soil.

## 3. Holding Tanks

- a. Holding tanks may be used for single family homes and other buildings with limited water use under the following conditions:
  - 1. The holding tank shall be installed in accordance with Minnesota Rules Section 7080.2290.
  - 2. A remote reading water meter shall be installed to continuously record indoor water use.
  - 3. The owner shall declare who the licensed liquid waste hauler will be to pump and haul the waste to a licensed treatment facility or approved land application site. This requirement of having a contract with a licensed maintenance business is waived if the owner is a farmer who is exempt from licensing

- under Minnesota Statutes, section 115.56, subdivision 3, paragraph (b), clause (3).
- 4. The holding tank shall be regularly pumped. Records shall be kept for a period of three (3) years and presented to the department upon request.
- 5. The pumper shall certify each date the tank is pumped; the volume of the liquid waste removed the treatment facility or land application to which the waste was discharged, and the water meter reading at the time of pumping. The pumper must report to the Department that the holding tank is pumped with the preceding information included on or with the invoice.
- b. Failure to meet these requirements will result in a violation of the Nobles County Planning and Zoning Ordinance.

## 719.10 Variances

- 1. Variance Requests. A property owner may request a variance from the standards as specified in this ordinance pursuant to county policies and procedures.
- Affected Agency. Variances that pertain to the standards and requirements of the State of Minnesota must be approved by the affected State Agency pursuant to the requirements of the State Agency.
- 3. Board of Adjustment. The Board of Adjustment shall have the authority only to consider variances to horizontal setbacks from property lines, rights of way, structures, or buildings. Variances shall only be permitted when they are in harmony with the general purposes and intent of this Ordinance where there are practical difficulties or particular hardship in meeting the strict letter of this Ordinance. Variance requests to deviate from the design flow determination procedures in Minnesota Rules, Chapter 7081.0110 if the deviation reduces the average daily estimated flow from greater than 10,000 gallons per day to less than 10,000 gallons per day, or to provisions in 7080.2150, Subp. 2 and 7081.0080, Subp. 2 through 5 regarding the vertical separation required beneath the treatment and dispersal soil system and saturated soil or bedrock from the required three feet of unsaturated soil material (except as provided in 7082.1700, Subp. 4D) must be approved by MPCA. Variances to wells and water supply lines must be approved by the Minnesota Department of Health.
- 4. Any property owner requesting relief from the strict application of the provisions in this Ordinance must complete and submit an Application for

Variance to the Department on a form provided by the Department. The variance request must include, as applicable:

- a. A statement identifying the specific provision or provisions in the ordinance from which the variance is requested;
- b. A description of the hardship that prevents compliance with the rule;
- The alternative measures that will be taken to achieve a comparable degree of compliance with the purposes and intent of the applicable provisions;
- d. The length of time for which the variance is requested;
- e. Cost considerations only if a reasonable use of the property does not exist under the term of the Ordinance; and
- f. Other relevant information requested by the Department as necessary to properly evaluate the variance request.
- 5. The appropriate fee shall be paid at the time of submittal of the application to receive consideration by the Board of Adjustment
- 6. Upon receipt of the variance application, the Department shall decide if a site investigation conducted by the Department will be necessary. After the necessary information has been gathered, the Department shall make a written recommendation to approve or deny the variance to the Board of Adjustment.
- 7. The Board of Adjustment shall make the final decision after conducting a public hearing. The variance may be granted provided that:
  - a. The condition causing the demonstrated hardship is unique to the property and was not caused by the actions of applicant;
  - The granting of the variance will not be contrary to the public interest or damaging to the rights of other persons or to property values in the vicinity;
  - c. The property owner would have no reasonable use of the land without the variance;
  - d. The granting of the variance would not allow a prohibited use; and
  - e. The granting of the variance would be in accordance with Minnesota Rules, Chapters 7080, 7081, and 7082.
- 8. In granting a request for a variance, the Board of Adjustment may attach such conditions as it deems necessary to conform to the purpose and intent of this Ordinance.
- 9. Any violation of the terms and conditions of a variance issued pursuant to this Ordinance, or any violation of any provision of this Ordinance relating to the specific issue of the variance, shall result in immediate revocation of the variance.

- 10. Any variance granted shall automatically expire if the system is not installed within one year of the grant of the variance.
- 11. An appeal from any order, requirement, decision, or determination of the Board of Adjustment must be in accordance with its policies and procedures.

## 719.11 SSTS Permitting

- Permit Required. It is unlawful for any person to construct, install, modify, replace, or operate a SSTS without the appropriate permit from the Nobles County Environmental Services. The issuing of any permit, variance, or conditional use under the provisions of this ordinance shall not absolve the applicant of responsibility to obtain any other required permit.
- 2. SSTS Permit. A SSTS permit shall be obtained by the property owner or an agent of the property owner from the County prior to the installation, construction, replacement, modification, alteration, repair, or capacity expansion of a SSTS. The purpose of this permit is to ensure that the proposed construction activity is sited, designed, and constructed in accordance with the provisions of this Ordinance by appropriately certified and/or licensed practitioner(s).
- 3. Activities Requiring a Construction Permit. A SSTS permit is required for installation of a new SSTS, for replacement of an existing SSTS, or for any repair or replacement of components that will alter the original function of the system, change the treatment capacity of the system, change the location of the system, or otherwise change the original system's design, layout, or function.
- 4. Construction Permit Required to Obtain a Building Permit. For any property on which a SSTS permit is required, approval and issuance of a valid SSTS Construction Permit must be obtained before a building or land use permit may be issued by the Department.
- 5. Conformance to Prevailing Requirements. Any activity involving an existing system that requires a Construction Permit shall require that the entire system be brought into compliance with this Ordinance.
- 6. Permit Application Requirements. SSTS Permit applications shall be made on forms provided by the Environmental Services Department and signed by the applicant and an appropriately certified practitioner including the practitioner's certification number and date of expiration. The applications shall include the documents listed in items A through E below.
  - a. Name, mailing address, and telephone number, of property owner.
  - b. Property Identification Number, address and legal description of the property location.
  - c. Site Evaluation Report as described in Minnesota Rules, Chapter 7080.1730

- d. Design Report as described in Minnesota Rules, Chapter 7080.2430.
- e. Management Plan as described in Minnesota Rules, Chapter 7082.0600.
- f. Name, mailing address, telephone number of the system designer and system installer.
- g. Any other information requested by the Department that is pertinent to the application.
- 7. Application Review and Response. The Department shall review a permit application and supporting documents.
  - a. Upon satisfaction that the proposed plan and design information conform to the provisions of this Section, the Department shall issue a septic permit authorizing construction of the SSTS as designed.
  - b. In the event there is a significant change to the approved application, the designer must file an amended application to the Department detailing the changed conditions for review and approval or denial prior to initiating or continuing construction, modification, or operation. The Department shall complete the review of the amended application within 15 business days of receipt of the amended application.
  - c. If the permit application is incomplete or does not meet the requirements of this section, the Department shall deny the application. A written notice of denial shall be provided to the applicant, which must state the reason for the denial.
- 8. Appeal. The applicant may appeal the Departments decision to deny the SSTS Permit in accordance with the County's established policies and appeal procedures.
- 9. Permit Expiration. The Septic Permit is valid for a period of one (1) year from its date of issue. Satisfactory completion of construction shall be determined following a final inspection. After the final inspection, a Certificate of Compliance will be issued to the property owner by the Department, that the construction or installation of the system was completed in reasonable conformance with the approved design.
- 10. Extensions and Renewals. The Department may grant an extension of the Construction Permit if the construction has commenced prior to the original expiration date of the permit. The permit may be extended for a period of no more than 12 months.
- 11. Transferability. A SSTS Permit shall not be transferred to a new owner. The new owner must apply for a new Construction Permit in accordance with this section.
- 12. Suspension or Revocation. The Department may suspend or revoke a Construction Permit issued under this section for any false statements, misrepresentations of facts on which the Construction Permit was issued, or

unauthorized changes to the system design that alter the original function of the system, change the treatment capacity of the system, change the location of the system, or otherwise change the original system's design, layout, or function. A notice of suspension or revocation and the reasons for the suspension or revocation shall be conveyed in writing to the permit holder. If suspended or revoked, installation or modification of a treatment system may not commence or continue until a valid Construction Permit is obtained.

13. Posting. The Construction Permit shall be posted on the property in such a location and manner so that the permit is visible and available for inspection until construction is completed and certified.

## 719.12 Operating Permit

- 1. SSTS Requiring an Operating Permit. An Operating Permit shall be required of all owners of new holding tanks, MSTS, Type IV systems, Type V systems, or any other system deemed by the Department to require operational oversight. Sewage shall not be discharged to a holding tank or MSTS until the Environmental Services certifies that the MSTS or holding tank was installed in substantial conformance with the approved plans, receives the final record drawings of the MSTS, and a valid Operating Permit is issued to the owner.
- 2. Permit Application Requirements. Application for an Operating Permit shall be made on a form provided by the Nobles County Environmental Services Department including:
  - a. Property owner name, mailing address, and telephone number.
  - b. Property Identification number, address and legal description of the property.
  - c. SSTS Permit number and date of issue
  - d. Final record drawings of the treatment system
  - e. Owners of holding tanks must submit a copy of a valid executed monitoring and disposal contract with a licensed maintenance business
  - f. Monitoring and Disposal Contract
  - g. Any other information requested by the Department that is pertinent to the application.
- 3. Owners of holding tanks shall provide to the Nobles County Environmental Services Department a copy of a valid monitoring and disposal contract executed between the owner and a licensed maintenance business, which guarantees the removal of the holding tank contents in a timely manner that prevents an illegal discharge in accordance with Minnesota Rules, Chapter 7082.0100. This requirement of having a contract with a licensed maintenance business is waived if the owner is a farmer who is exempt from

- licensing under Minnesota Statutes, section 115.56, subdivision 3, paragraph (b), clause (3).
- 4. SSTS existing prior to the effective date of this ordinance. All SSTS existing prior to the effective date of this ordinance shall require an operating permit upon transfer of ownership, replacement, any modification or expansion that requires a permit, or following any SSTS enforcement action.
- 5. Department Response. The Department shall review the record drawings, operation and maintenance manual, management plan, maintenance and servicing contract, and any other pertinent documents as appropriate for accuracy and completeness. If any deficiencies are identified, the operating permit shall be denied until the deficiencies are corrected to the satisfaction of the Department. If the submitted documents fulfill the requirements, the Department shall issue an operating permit within 15 business days of receipt of the permit application.
- 6. Operating Permit Terms and Conditions. The Operating Permit shall include the following (see Minnesota Rules, Chapter 7082.0600, Subp.2.B):
  - a. System performance requirements;
  - b. System monitoring requirements;
  - c. System maintenance requirements and schedules;
  - d. System compliance limits and boundaries;
  - e. Reporting requirements;
  - f. Department notification requirements for non-compliant conditions;
  - g. Valid contract between the owner and a licensed maintenance business:
  - h. Disclosure, location and condition of acceptable soil treatment and dispersal system site;
  - i. Descriptions of acceptable and prohibited discharges.
- 7. Operating Permit Expiration and Renewal
  - a. Operating Permits shall be valid for five (5) years.
  - b. An Operating Permit must be renewed prior to its expiration. If not renewed, the Department may require the system to be removed from service or operated as a holding tank until the permit is renewed. If not renewed within in (90) calendar days of the expiration date, the County may require that the system be abandoned in accordance with Minnesota Rules Chapter 7080.2500.
  - c. The Department shall notify the holder of an operating permit at least 90 calendar days prior to expiration of the permit. The Owner must apply for renewal at least 30 calendar days before the expiration date.

- d. Application shall be made on a form provided by the Department including:
  - 1. Applicant name, mailing address and phone number;
  - 2. Property address and legal description;
  - 3. Operating permit and SSTS permit number;
  - 4. Any and all outstanding Compliance Monitoring Reports as required by the Operating Permit;
  - Certified treatment system inspection signed and/or sealed by a certified designer, maintenance contractor, or operator at the discretion of the County;
  - 6. Any revisions made to the operation and maintenance manual;
  - 7. Payment of application review fee as determined by the County;
  - 8. Description of type of maintenance or repair, and date performed.
- 8. Amendments to existing permits not allowed. The County may not amend an existing permit to reflect changes in this Ordinance until the permit term has expired and is renewed, unless an amendment is necessary to eliminate an imminent threat to public health or safety.
- 9. Transfers. The operating permit may not be transferred. A new owner shall apply for an operating permit in accordance with Section 719.12 of this Ordinance. The Department shall not terminate the current permit until 60 calendar days after the date of sale unless an imminent threat to public health and safety exists. To consider the new owner's application, the Department may require a performance inspection of the treatment system certified by a licensed inspector or qualified employee.

## 10. Suspension or Revocation

- a. The Department may suspend or revoke any operating permit issued under this section for any false statements or misrepresentations of facts on which the Operating Permit was issued.
- b. Notice of suspension revocation and the reasons for revocation shall be conveyed in writing to the owner.
- c. If suspended or revoked, the Department may require that the treatment system be removed from service, operated as a holding tank, or abandoned in accordance with Minnesota Rules Chapter 7080.2500.

At the Department's discretion, the operating permit may be reinstated or renewed upon the owner taking appropriate corrective actions.

## 11. Compliance Monitoring

- a. Performance monitoring of a SSTS shall be determined as indicated in the monitoring plan.
- b. A monitoring report shall be prepared and certified by the appropriate licensed individuals identified within the monitoring plan. The report shall be submitted to the Department on a form provided by the Department on or before the compliance reporting date stipulated in the operating permit. The report shall contain a description of all maintenance and servicing activities performed since the last compliance monitoring report as described below:
  - 1. Owner name, address and telephone number;
  - 2. Property address and legal description;
  - 3. Operating Permit number;
  - 4. Average daily flow since last compliance monitoring report;
  - 5. Description of type of maintenance and date performed;
  - 6. Description of samples taken (if required), analytical laboratory used, and results of analyses;
  - 7. Problems noted with the system and actions proposed or taken to correct them:
  - 8. Name, signature, business license, and license number of the licensed professional who performed the work.

## 719.13 Abandonment Certification

1. Purpose. The purpose of the System Abandonment Certification is to ensure that a treatment system no longer in service is abandoned, within a reasonable time following decommissioning, and in a manner that protects public health, safety and water quality. It also terminates all permits associated with the system.

## 2. Abandonment Requirements

- a. Whenever the use of a SSTS or any system component is discontinued as the result of a system repair, modification, replacement or decommissioning following connection to a municipal or private sanitary sewer, or condemnation or demolition of a building served by the system, further use of the system or any system component for any purpose under this Ordinance shall be prohibited.
- b. Continued use of a sewage tank where the tank is to become an integral part of a replacement system or a sewage treatment system requires certification of the tank by a licensed inspection business that

- the tank is watertight and in compliance with all applicable SSTS tank standards.
- c. An owner of an SSTS must retain a licensed business to abandon all components of the treatment system whenever the use of a SSTS or any system component is discontinued. System abandonment shall be completed in accordance with Minnesota Rules, Chapter 7080.2500. No prior notification of the Department of an owner's intent to abandon a system is necessary.
- d. A report of abandonment certified by the licensed business shall be submitted to the Department within 30 calendar days of system abandonment. The report shall include:
  - 1. Owner's name, mailing address and telephone number;
  - 2. Property address;
  - 3. System SSTS permit and operating permit numbers;
  - 4. The reason(s) for abandonment;
  - 5. A brief description of the abandonment methods used, description of the system components removed or abandoned in place, and disposition of any materials or residuals;
  - 6. A certified statement from a licensed business that the abandonment was completed in accordance with Minnesota Rules, Chapter 7080.2500.
- 3. Abandonment Certificate. Upon receipt of an abandonment report and its determination that the SSTS has been abandoned according to the requirements of this Ordinance, the Department shall issue an abandonment certificate. If the abandonment is not completed according the requirements of this ordinance the County shall notify the owner of the SSTS of the deficiencies, which shall be corrected within 30 calendar days of the notice.

## 719.14 Management Plans

- 1. Purpose. The purpose of management plans is to describe how a particular SSTS is intended to be operated and maintained to sustain the performance required. The plan is to be provided by the certified designer to the system owner when the treatment system is commissioned.
- 2. SSTS Requiring Management Plans. Management plans are required for all new or replacement SSTS. The management plan shall be submitted to the Department with the construction permit application for review and approval. The Department shall be notified of any system modifications made during construction and the management plan revised and resubmitted at the time of final construction certification

- 3. Required Contents of a Management Plan. Management plans shall include the following: Minnesota Rules, Chapter 7082.0600, Subp.1:
  - a. Operating requirements describing tasks that the owner can perform and tasks that a licensed service provider or maintainer must perform;
  - b. Monitoring requirements;
  - c. Maintenance requirements including maintenance procedures and a schedule for routine maintenance:
  - d. Statement that the owner is required to notify the Department when the management plan requirements are not being met;
  - e. Disclosure of the location and condition of the additional soil treatment and dispersal area on the owner's property or a property serving the owner's residence;
  - f. Other requirements as determined by the Department.
- 4. Requirements for Systems not Operated under a Management Plan Minnesota Rules, Chapter 7082.0100, Subp. 3.(L)

SSTS that are not operated under a management plan or operating permit must have treatment tanks inspected and provide for the removal of solids if needed every three (3) years. Solids must be removed when their accumulation meets the limit described in Minnesota Rules, Chapter 7080.2450.

## 719.15 Compliance Management

1. PUBLIC EDUCATION OUTREACH

Programs shall be provided by the Department and/or others to increase public awareness and knowledge of SSTS. Programs may include distribution of educational materials through various forms of media and SSTS workshops focusing on SSTS planning, construction, operation, maintenance, and management.

## 2. COMPLIANCE INSPECTION PROGRAM

a. Department Responsibility

It is the responsibility of the Department, or its agent, to perform various SSTS compliance inspections periodically to assure that the requirements of this Ordinance are met.

- b. SSTS compliance inspections must be performed:
  - 1. To ensure compliance with applicable requirements;
  - 2. To ensure system compliance before issuance of a permit for addition of a bedroom unless the permit application is made during the period of November 1 to April 30, provided a compliance inspection is performed before the following June 1 and the applicant submits a certificate of compliance by the following September 30;

- 3. For all new SSTS construction or replacement;
- 4. For an evaluation, investigation, inspection, recommendation, or other process used to prepare a disclosure statement if conducted by a party who is not the SSTS owner. Such an inspection constitutes a compliance inspection and shall be conducted in accordance with Minnesota Rules, Chapter 7082.0700 using the SSTS inspection report forms provided by MPCA.
- c. All compliance inspections must be performed and signed by licensed inspection businesses or qualified employees certified as inspectors.
- d. The Department shall be given access to enter a property at any reasonable time to inspect and/or monitor the SSTS system. As used in this paragraph, "property" does not include a residence or private building. The Department shall notify the owner of the Department's intent to inspect the SSTS in advance of the intended inspection.
- e. No person shall hinder or otherwise interfere with the Department's employees in the performance of their duties and responsibilities pursuant to this ordinance. Refusal to allow reasonable access to the property by the Department shall be deemed a separate and distinct offense.

## 3. New Construction or Replacement

- a. Compliance inspections must be performed on new or replacement SSTS to determine compliance with Minnesota Rules, Chapters 7080 or 7081. SSTS found to be noncompliant with other applicable requirements must be repaired or replaced according to the Department's requirements.
- b. Chapter 7082.0700, Subp. 3(2) requires that a vertical separation report include verifications by two independent parties, which may be licensed inspection businesses and/or a qualified employee inspector with jurisdiction. If there is a dispute between the two verifying inspectors, the disputing parties must follow the local dispute resolution procedures. If no local dispute resolution procedures exist, the dispute resolution procedure described in 7080.0700, Subp. 5 must be followed:
- c. It is the responsibility of the SSTS owner or the owner's agent to notify the Department two (2) calendar days prior to any permitted work on the SSTS.
- d. A Certificate of Compliance for new SSTS construction or replacement, which shall be valid for five (5) years, shall be issued by the Department if the Department has reasonable assurance that the system was built in accordance with the applicable requirements as specified in the construction permit.

- e. The certificate of compliance must include a certified statement by the certified inspector or qualified employee who conducted the inspection that the SSTS is or is not in compliance with the ordinance requirements. If the SSTS is determined not to be in compliance with the applicable requirements, a notice of noncompliance must be issued to the owner which includes a statement specifying those ordinance provisions with which the SSTS does not comply.
- f. The certificate of compliance or notice of noncompliance must be submitted to the Department no later than 15 calendar days after the date the inspection was performed. The Department shall deliver the certificate of compliance or notice of noncompliance to the owner or the owner's agent within 15 business days of receipt from the certified inspector. No SSTS shall be placed into operation until a valid certificated of compliance has been issued.
- g. Certificates of compliance for new construction or replacement shall remain valid for five (5) years from the date of issue unless the Department finds evidence of noncompliance.

## 4. Existing Systems

- a. Compliance inspections shall be required when any of the following conditions occur:
  - 1. When a construction permit is required to repair, modify, or upgrade an existing system;
  - 2. Any time there is an expansion of use of the building being served by an existing SSTS which may impact the performance of the system;
  - Any time there is a change in use of the property being served by an existing SSTS which may impact the performance of the system;
  - 4. At any time as required by this Ordinance or the Department deems appropriate such as upon receipt of a complaint or other notice of a system malfunction.
- b. Compliance inspections shall be considered for the following:
  - 1. When an operating permit is to be renewed;
  - 2. At the time of property sale or transfer;
  - 3. During systematic lake or area-wide SSTS surveys by the Department, and/or;
  - Anytime the Department deems appropriate such as upon receiving a complaint or other information of system malfunction or failure.

- c. Compliance inspections of existing SSTS shall be reported on the inspection report forms provided by MPCA. The following conditions, must be assessed, or verified:
  - 1. Watertightness assessment of all treatment tanks including a leakage report;
  - 2. Vertical separation distance between the bottom of the soil treatment and dispersal system and the periodically saturated soil or bedrock including a vertical separation verification report;
  - 3. Chapter 7082.0700, Subp. 3(2) requires that a vertical separation report include verifications by two independent parties, which may be licensed inspection businesses and/or a qualified employee inspector with jurisdiction. If there is a dispute between the two verifying inspectors, the disputing parties must follow the local dispute resolution procedures. If no local dispute resolution procedure exist, the dispute resolution procedure described in 7080.0700, Subp. 5 must be followed.
  - 4. Sewage backup, surface seepage, or surface discharge including a hydraulic function report;
  - 5. The requirements for the inspection reports in this section are described in Minnesota Rules, Chapter 7082.0700, Subp. 4(B).
- d. The certificate of compliance must include a certified statement by a qualified employee or licensed inspection business, indicating whether the SSTS is in compliance with the ordinance requirements. If the SSTS is determined not to be in compliance with the applicable requirements, a notice of noncompliance must include a statement specifying those ordinance provisions with which the SSTS does not comply. A construction permit application must be submitted to the Department if the required corrective action is not a minor repair.
- e. The certificate of compliance or notice of noncompliance must be submitted to the Department no later than fifteen (15) calendar days after the date the inspection was performed. The Department shall deliver the certificate of compliance or notice of noncompliance to the owner or the owner's agent within fifteen (15) business days of receipt from the licensed inspection business.
- f. Certificates of compliance for existing SSTS shall remain valid for three
   (3) years from the date of issue unless the Department finds evidence of noncompliance.
- g. SSTS on properties sold or transferred to new owners should be repaired, replaced, or upgraded as determined by a compliance inspection, records search, or other means acceptable to the Department that are conducted prior to ownership transfers. The determination of need to repair, replace, or upgrade should proceed in

- a manner that does not needlessly delay or otherwise interfere with the property sale transaction.
- h. The Department shall be given access to enter a property at any reasonable time to inspect and/or monitor the SSTS system. The Department shall notify the owner of the Department's intent to inspect the SSTS in advance of the intended inspection.

## 719.16 Transfer of Properties

- Whenever a conveyance of land upon which a dwelling is located, or a tract of land upon which a structure that is required to have an SSTS occurs, the following requirements shall be met:
  - a. A compliance inspection has been performed and a Certificate of Compliance has been issued by the Department within three (3) years for SSTS older than five years or within five (5) years if the system is less than five (5) years old prior to the intended sale or transfer of the property unless evidence is found identifying an Imminent Threat to Public Health and Safety;
  - b. The compliance inspection must have been preformed by a qualified employee of the Department or a licensed inspection business following procedures described in this ordinance;
  - c. The seller of the property must disclose in writing information about the status and location of all known SSTS on the property to the buyer on a form acceptable to the Department;
  - d. If the seller fails to provide a Certificate of Compliance, the seller shall provide the buyer sufficient security in the form of an escrow agreement to assure the installation of a complying SSTS. The security shall be placed in an escrow with a licensed real estate closer, licensed attorney-at-law, or federal or state chartered financial institution. The amount escrowed shall be equal to 150% of a written estimate to install a complying SSTS provided by a licensed and certified installer, or the amount escrowed shall be equal to 110% of the written contract price for the installation of a complying SSTS provided by a licensed and certified installer. After a complying SSTS has been installed and a certificate of compliance issued, the Department shall provide the escrow agent a copy of the Certificate of Compliance.
- 2. The compliance portion of the Certificate of Compliance need not be completed if the sale or transfer involves the following circumstances:
  - a. The affected tract of land is without buildings or contains no dwellings or other buildings with plumbing fixtures.

- The transfer does not require the filing of a Certificate of Real Estate Value, as described in Minnesota Statutes, Section 272.115, subdivision 1.
- c. The transfer is a foreclosure or tax forfeiture.
- d. The sale or transfer completes a contract for deed or purchase agreement entered into prior to the effective date of this Ordinance. This subsection applies only to the original vendor and vendee on such a contract.
- e. Any dwellings or other buildings that are connected exclusively to a municipal wastewater treatment system; any dwellings or other buildings that are located within the jurisdiction of a County approved agreement requiring exclusive connection to the wastewater treatment system of any municipality; or, any dwellings or other buildings that are connected exclusively to an approved wastewater treatment facility other than an individual sewage treatment system.
- 3. All property conveyances subject to this ordinance when SSTS compliance cannot be determined due to frozen soil conditions, shall require a winter agreement, which includes an application for an SSTS permit and an agreement to complete a compliance inspection by the following June 1st by a licensed inspection business. If upon inspection the SSTS is found to be in compliance, the permit fee will be refunded. If upon inspection the system is found to be non-compliant, an escrow agreement must be established in accordance with this ordinance, and the system upgraded.
- 4. The responsibility for filing the completed compliance portion of the Certificate of Compliance, or for upgrading a system found to be noncompliant shall be determined by the buyer and seller. Buyer and seller shall provide the Department with a signed statement indicating responsibility for completing the compliance portion of the certification and for upgrading a system found to be non-conforming.
- 5. Neither the issuance of permits, certificates of compliance, or notices of noncompliance as requested or issued shall be construed to represent a guarantee or warranty of the system's operation or effectiveness. Such certificates signify that the system in question is or has been designed and installed in compliance or non-compliance with the provisions of these standards and regulations.

## 719.17 Enforcement

- Enforcement of the Subsurface Treatment System Regulations shall be in accordance with Section 8 Enforcement of the Nobles County Land Use Ordinance.
- 2. Cause to Issue a Notice of Violation. Any person, firm, agent, or corporation who violates any of the provisions of this Ordinance, or who fails, neglects, or refuses to comply with the provisions of this Ordinance, including violations of conditions and safeguards, or who knowingly makes any material false statement or knowing omission in any document required to be submitted under the provisions hereof, shall be guilty of a misdemeanor and upon conviction thereof, shall be punishable as defined by Minnesota State Statutes. Each day that a violation exists shall constitute a separate offense.
- 3. Notice of Violation. The Department shall serve, in person or by mail, a notice of violation to any person determined to be violating provisions of this Ordinance. The notice of violation shall contain:
  - a. A statement documenting the findings of fact determined through observations, inspections, or investigations;
  - b. A list of specific violation(s) of this Ordinance;
  - c. Specific requirements for correction or removal of the specified violation(s);
  - d. A mandatory time schedule for correction, removal and compliance with this ordinance.
- 4. State Notification of Violation. In accordance with state law, the Department shall notify the MPCA of any inspection, installation, design, construction, alteration or repair of an SSTS by a licensed/certified person or any septage removal by a licensed pumper that is performed in violation of the provisions of this Ordinance.
- 5. Cease and Desist Orders. Cease and desist orders may be issued when the Department has probable cause that an activity regulated by this or any other County Ordinance is being or has been conducted without a permit or in violation of a permit. When work has been stopped by a cease and desist order, the work shall not resume until the reason for the work stoppage has been completely satisfied, any administrative fees paid, and the cease and desist order lifted.

## 719.18 Cost and Reimbursements

If the Department is required to remove or abate an imminent threat to public health or safety, the Department may recover all costs incurred in removal or abatement in a civil action, including legal fees; at the discretion of the County Board, the cost of an enforcement action under this ordinance may be assessed and charged against the real property on which the public health

nuisance was located. The County Auditor shall extend the cost as assessed and charged on the tax roll against said real property.

## 719.19 Record Keeping

The County shall maintain a current record of all permitted systems. The record shall contain all permit applications, issued permits, fees assessed, variance requests, certificates of compliance, notices of noncompliance, enforcement proceedings, site evaluation reports, design reports, record drawings, management plans, maintenance reports, an annual list of all sewage tanks installed in the county sorted by licensed installation businesses, and other records relevant to each system.

## 719.20 Annual Report

The department shall provide an annual report, of the previous calendar year's SSTS permitting activities, to the MPCA by the date specified by the MPCA as required.

## 719.21 Fees

From time to time, the County Board shall establish fees for activities undertaken by the Department pursuant to this Ordinance. Fees shall be due and payable at a time and in a manner to be determined by the Department.

## 719.22 Interpretation

In their interpretation and application, the provisions of this Ordinance shall be held to be minimum requirements and shall be liberally construed in favor of the County and shall not be deemed a limitation or repeal of any other powers granted by Minnesota Statutes.

## 719.23 Severability

If any section, clause, provision, or portion of this ordinance is adjudged unconstitutional or invalid by a court of law, the remainder of this Ordinance shall not be affected and shall remain in full force.

## 719.24 Abrogation and Greater Restrictions

It is not intended by this Ordinance to repeal, abrogate, or impair any other existing County ordinance, easements, covenants, or deed restrictions. However, where this Ordinance imposes greater restrictions, the provisions of this Ordinance shall prevail. All other Ordinances inconsistent with this ordinance are hereby repealed to the extent of the inconsistency only.

#### 719.25 Ordinance Repealed

The Nobles County previous ordinance for the regulation of Individual Sewage Treatment Systems of the County is hereby repealed.

## 719.26 Adoption

719.26	Adoption
	The Nobles County Subsurface Sewage Treatment Program Ordinance is hereby adopted by Nobles County Board of Commissioners on the day of, 20
	erson, Nobles County Board of issioners
ATTES	π:
<b>EFFEC</b>	TIVE DATE:, 20