



ADDENDUM NO. 1


1112 north 5th Street
minneapolis, mn 55411
Phone: (612) 343-5965

1624 north riverfront drive
mankato, mn 56001
Phone: (507) 625-7869

For Project: Nobles Co Government Center Generator Replacement
EDI-Dolejs No.: 22-075
Owner: Nobles County
Worthington, MN

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am a duly licensed Professional Engineer under the laws of the State of Minnesota.

Date: 4/11/23


Jay Hruby P. E.

License No. 40290

This Addendum is added to and shall become a part of the Contract Documents dated **March 9, 2023**. Bidders shall acknowledge receipt of this Addendum in their Bid Form. Failure to comply may result in rejection of the Bid.

**NOTE: THE BID DATE HAS NOT BEEN CHANGED.
THE BID TIME HAS NOT BEEN CHANGED.**

**THE BID DATE IS: 04/19/2023
THE BID TIME IS: 2:00 PM**

CHANGES TO THE PROJECT MANUAL:

Section 23 0900 – Instrumentation and Control for HVAC

1. Clarification: Division 23 Contractor shall furnish, deliver, install and wire motorized ventilation dampers and fuel oil solenoid valves. Drawing E3.1 plan note #20 calls for the Div 26 contractor to furnish and install the damper control relay box. Drawing E3.1 plan note #25 calls for the Div 26 contractor to furnish connections to the fuel day tank for power and control.

CHANGES TO THE DRAWINGS:

Drawing M2.1 – Partial Floor Plan – Mechanical Demolition

1. Change Plan Note 4 to read as follows: “Disconnect and remove existing silencer and exhaust piping. Patch pipe openings in exterior wall with finish to match existing conditions”.

APPROVED MANUFACTURER SUBSTITUTIONS: Naming below does not guarantee approval, substitutions must meet requirements of the specifications and plans.

Section:Item:

X

X

Manufacturer:

X

END OF ADDENDUM NO. 1